

VOC Content Test Certificate

Monday, 5th March 2018

Supplier: Robert Designs International & Maxisil (3/204 Boneo Td, Rosebud, VIC, 3939)

Sample Description: Maxisil N Natural Stone

Date Tested: February 2018 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:

<p align="center">Specification</p> <p align="center">Green Building Council of Australia Green Star Design & As Built V1.1 13.1.1 Green Star Interiors V1.1 12.1.1B</p>	<p align="center">Maxisil N Natural Stone</p>
<p align="center">General Purpose Adhesives and Sealants: 50 grams per Litre as VOC content per material</p>	<p align="center">46 grams per Litre as VOC content</p>

We hereby certify that Maxisil N Natural Stone is below the VOC Content limits of chosen category specified by Green Star Design, Green Building Council of Australia



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Tuan Duong
BE (Chem. Eng.)
Consultant



Nick Joy
BSc (Hons)
Consultant

CV180263